

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3293494

Type : Form

User Type : User

Date & Time : 6/25/2023 9:06 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	06.25.2023
Time of Reading	9:02 AM
Staff Member Taking Reading	Michaela Greenly
Water Check - Free Chlorine (1.5 - 3.0 ppm)	0
pH Test (7.2 - 7.8)	7
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	174
Water Temperature (F)	88
Air Temperature (F)	
Saturation Index	
Water Clarity	Great
Influent Pressure	25
Effluent Pressure	28
Pressure Differential	5
Chemicals and Amounts Added (Opening or Close)	5 scoops of shock
Were any calibrations made? If yes, what was the calibration set as?	Reset chlorinator/backwash
Any other notes/comments	Shallow
Notified AD/MAA or maintenance? If yes, who?	