

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3297089

Type : Form

Date & Time : 6/27/2023 8:28 AM

Instructions : Review and customize this form to meet your needs.

User Type : User

Name : PublicDesoto

Question	Response
Date of Reading	06.27.2023
Time of Reading	8:00 AM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.7
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	45
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	260
Flow Rate	Good
ORP	655
Water Temperature (F)	71
Air Temperature (F)	88
Saturation Index	Good
Water Clarity	Great
Influent Pressure	23
Effluent Pressure	10
Pressure Differential	13
Chemicals and Amounts Added (Opening or Close)	None
Were any calibrations made? If yes, what was the calibration set as?	None
Any other notes/comments	n/a
Notified AD/MAA or maintenance? If yes, who?	No