

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3316870

Type : Form

Date & Time : 7/8/2023 10:03 AM

Instructions : Review and customize this form to meet your needs.

User Type : User

Name : PublicDesoto

Question	Response
Date of Reading	07.08.2023
Time of Reading	10:01 AM
Staff Member Taking Reading	Richmond Spencer Deep End CL - 1.7
Water Check - Free Chlorine (1.5 - 3.0 ppm)	3.5
pH Test (7.2 - 7.8)	7.3
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	240
Flow Rate	Good
ORP	650
Water Temperature (F)	71
Air Temperature (F)	88
Saturation Index	Good
Water Clarity	Great
Influent Pressure	23
Effluent Pressure	13
Pressure Differential	10
Chemicals and Amounts Added (Opening or Close)	Richmond Spencer
Were any calibrations made? If yes, what was the calibration set as?	No
Any other notes/comments	No
Notified AD/MAA or maintenance? If yes, who?	No