

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3318403

Type : Form

Date & Time : 7/9/2023 1:39 PM

Instructions : Review and customize this form to meet your needs.

User Type : User

Name : PublicDesoto

Question	Response
Date of Reading	07.09.2023
Time of Reading	1:34 PM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.7
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	230
Flow Rate	Good
ORP	655
Water Temperature (F)	71
Air Temperature (F)	90
Saturation Index	Good
Water Clarity	Great
Influent Pressure	23
Effluent Pressure	13
Pressure Differential	10
Chemicals and Amounts Added (Opening or Close)	Accu Tabs
Were any calibrations made? If yes, what was the calibration set as?	No
Any other notes/comments	No
Notified AD/MAA or maintenance? If yes, who?	NO