

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3324582

Type : Form

User Type : User

Date & Time : 7/12/2023 1:16 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

| Question | Response |
|--|---|
| Date of Reading | 07.12.2023 |
| Time of Reading | 1:10 PM |
| Staff Member Taking Reading | Richmond Spencer (Deep End CL 2.8) |
| Water Check - Free Chlorine (1.5 - 3.0 ppm) | 1.0 |
| pH Test (7.2 - 7.8) | 7.2 |
| Total Chlorine = FC + CC | |
| Cyanuric Acid (30-50 ppm) | 40 |
| Total Alkalinity (80-120 PPM) | 110 |
| Calcium Hardness (200-400 PPM) | 270 |
| Flow Rate | Good |
| ORP | 755 |
| Water Temperature (F) | 72 |
| Air Temperature (F) | 90 |
| Saturation Index | Good |
| Water Clarity | Great |
| Influent Pressure | 28 |
| Effluent Pressure | 5 |
| Pressure Differential | 23 |
| Chemicals and Amounts Added (Opening or Close) | Cl Added |
| Were any calibrations made? If yes, what was the calibration set as? | no |
| Any other notes/comments | Added wd40 to wheel on valve to see if it can rotates |
| Notified AD/MAA or maintenance? If yes, who? | no |