

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3326745

Type : Form

User Type : User

Date & Time : 7/13/2023 12:43 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.13.2023
Time of Reading	12:41 PM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.3
pH Test (7.2 - 7.8)	7.2
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	100
Calcium Hardness (200-400 PPM)	270
Flow Rate	NO FLOW ALERT
ORP	755
Water Temperature (F)	72
Air Temperature (F)	94
Saturation Index	Good
Water Clarity	Great
Influent Pressure	30
Effluent Pressure	5
Pressure Differential	25
Chemicals and Amounts Added (Opening or Close)	CL added (Manually Tested Levels Due to cat controller reading)
Were any calibrations made? If yes, what was the calibration set as?	no
Any other notes/comments	no
Notified AD/MAA or maintenance? If yes, who?	no