

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3347964

Type : Form

User Type : User

Date & Time : 7/25/2023 7:49 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.25.2023
Time of Reading	7:46 AM
Staff Member Taking Reading	matthew reed
Water Check - Free Chlorine (1.5 - 3.0 ppm)	3.9
pH Test (7.2 - 7.8)	7.5
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	859
Water Temperature (F)	89
Air Temperature (F)	72
Saturation Index	
Water Clarity	great
Influent Pressure	29
Effluent Pressure	8
Pressure Differential	21
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	changed filters out last night, Backwashedthis morning
Notified AD/MAA or maintenance? If yes, who?	