

# DeSoto Parks and Recreation

## Moseley Pool Chemical Log F2023-3354266

Type : Form

User Type : User

Date & Time : 7/28/2023 10:31 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.28.2023
Time of Reading	10:29 AM
Staff Member Taking Reading	matthew reed
Water Check - Free Chlorine (1.5 - 3.0 ppm)	3.1
pH Test (7.2 - 7.8)	7.3
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	871
Water Temperature (F)	90
Air Temperature (F)	89
Saturation Index	
Water Clarity	great
Influent Pressure	20
Effluent Pressure	11
Pressure Differential	11
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	
Notified AD/MAA or maintenance? If yes, who?	