

# DeSoto Parks and Recreation

## Moseley Pool Chemical Log F2023-3355185

Type : Form

User Type : User

Date & Time : 7/28/2023 4:48 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.28.2023
Time of Reading	4:47 PM
Staff Member Taking Reading	Matthew Reed
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.2
pH Test (7.2 - 7.8)	7.2
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	802
Water Temperature (F)	95
Air Temperature (F)	100
Saturation Index	
Water Clarity	great
Influent Pressure	20
Effluent Pressure	11
Pressure Differential	9
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	
Notified AD/MAA or maintenance? If yes, who?	