

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3313050

Type : Form

User Type : User

Date & Time : 7/6/2023 12:23 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.06.2023
Time of Reading	12:00 PM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	2.4
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	45
Total Alkalinity (80-120 PPM)	100
Calcium Hardness (200-400 PPM)	260
Flow Rate	GOOD
ORP	800
Water Temperature (F)	72
Air Temperature (F)	95
Saturation Index	GOOD
Water Clarity	GREAT
Influent Pressure	23
Effluent Pressure	10
Pressure Differential	13
Chemicals and Amounts Added (Opening or Close)	CL ADDED
Were any calibrations made? If yes, what was the calibration set as?	BACKWASHED PRIOR TO OPENING
Any other notes/comments	N/A
Notified AD/MAA or maintenance? If yes, who?	N/A