

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3322260

Type : Form

User Type : User

Date & Time : 7/11/2023 12:52 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.11.2023
Time of Reading	12:32 PM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	3.0
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	240
Flow Rate	Good
ORP	655
Water Temperature (F)	91
Air Temperature (F)	80
Saturation Index	
Water Clarity	great
Influent Pressure	15
Effluent Pressure	10
Pressure Differential	
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	
Notified AD/MAA or maintenance? If yes, who?	