

# DeSoto Parks and Recreation

## Moseley Pool Chemical Log F2023-3326406

Type : Form

User Type : User

Date & Time : 7/13/2023 10:24 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.13.2023
Time of Reading	8:00 AM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	0.2
pH Test (7.2 - 7.8)	7.2
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	90
Calcium Hardness (200-400 PPM)	280
Flow Rate	NO FLOW ALERT
ORP	655
Water Temperature (F)	72
Air Temperature (F)	88
Saturation Index	Good
Water Clarity	Great
Influent Pressure	30
Effluent Pressure	5
Pressure Differential	25
Chemicals and Amounts Added (Opening or Close)	Will shock / chlorinate pool before opening
Were any calibrations made? If yes, what was the calibration set as?	no
Any other notes/comments	Unable to backwash due to valve being stuck. Replacing filters this morning
Notified AD/MAA or maintenance? If yes, who?	no