

# DeSoto Parks and Recreation

## Moseley Pool Chemical Log F2023-3357914

Type : Form

User Type : User

Date & Time : 7/30/2023 4:26 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.30.2023
Time of Reading	4:24 PM
Staff Member Taking Reading	matthew reed
Water Check - Free Chlorine (1.5 - 3.0 ppm)	0.3
pH Test (7.2 - 7.8)	7.6
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	727
Water Temperature (F)	98
Air Temperature (F)	102
Saturation Index	
Water Clarity	great
Influent Pressure	15
Effluent Pressure	10
Pressure Differential	5
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	"failsafe operation ph down acid" keeps popping up
Notified AD/MAA or maintenance? If yes, who?	