

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3380470

Type : Form

User Type : User

Date & Time : 8/12/2023 9:48 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	08.12.2023
Time of Reading	9:44 AM
Staff Member Taking Reading	matthew reed
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.2
pH Test (7.2 - 7.8)	8.2
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	567
Water Temperature (F)	91
Air Temperature (F)	87
Saturation Index	
Water Clarity	great
Influent Pressure	15
Effluent Pressure	10
Pressure Differential	5
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	had to reset circulation. it was off. everything is operational now
Notified AD/MAA or maintenance? If yes, who?	