

From: donotreply@connect2mycloud.com
To: [Moore, Steve](#)
Subject: Form "Moseley Pool Chemical Log" Submission Received
Date: Thursday, June 15, 2023 12:08:21 PM

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

Form Submission

**DeSoto Parks and
Recreation**

**Moseley Pool Chemical
Log**

Type :Form

User Type :User

Name :PublicDesoto

Link :[Moseley Pool Chemical Log](#)

Instructions :Review and customize this form to meet your needs.

Questions	Response
Date of Reading	06.15.2023
Time of Reading	11:57 AM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	2.5
pH Test (7.2 - 7.8)	7.3
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	230
Flow Rate	Good
ORP	178
Water Temperature (F)	72
Air Temperature (F)	89
Saturation Index	Good
Water Clarity	Great
Influent Pressure	27
Effluent Pressure	7
Pressure Differential	20

Chemicals and Amounts Added (Opening or Close)	Shock Added to Deep End
Were any calibrations made? If yes, what was the calibration set as?	no
Any other notes/comments	no
Notified AD/MAA or maintenance? If yes, who?	no

© 2023 Connect2Concepts LLC.All rights reserved.Version 1.22.4.20