

**From:** [donotreply@connect2mycloud.com](mailto:donotreply@connect2mycloud.com)  
**To:** [Moore, Steve](#)  
**Subject:** Form "Moseley Pool Chemical Log" Submission Received  
**Date:** Thursday, June 22, 2023 2:19:11 PM

---

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

## Form Submission

**DeSoto Parks and  
Recreation**

**Moseley Pool Chemical  
Log**

**Type :**Form

**User Type :**User

**Name :**PublicDesoto

**Link :**[Moseley Pool Chemical Log](#)

**Instructions :**Review and customize this form to meet your needs.

| Questions                                   | Response                              |
|---|---------------------------------------|
| Date of Reading                             | 06.22.2023                            |
| Time of Reading                             | 2:17 PM                               |
| Staff Member Taking Reading                 | Richmond Spencer Deep End CL<br>- 1.1 |
| Water Check - Free Chlorine (1.5 - 3.0 ppm) | 1.0                                   |
| pH Test (7.2 - 7.8)                         | 7.4                                   |
| Total Chlorine = FC + CC                    |                                       |
| Cyanuric Acid (30-50 ppm)                   | 45                                    |
| Total Alkalinity (80-120 PPM)               | 110                                   |
| Calcium Hardness (200-400 PPM)              | 230                                   |
| Flow Rate                                   | Good                                  |
| ORP   | 655                                   |
| Water Temperature (F)                       | 71                                    |
| Air Temperature (F)                         | 90                                    |
| Saturation Index                            | Good                                  |
| Water Clarity                               | Great                                 |
| Influent Pressure                           | 23                                    |
| Effluent Pressure                           | 13                                    |

|  |                                   |
|--|-----------------------------------|
| Pressure Differential  | 10                                |
| Chemicals and Amounts Added (Opening or Close)                       | Will add CL during chemical break |
| Were any calibrations made? If yes, what was the calibration set as? | no                                |
| Any other notes/comments   | no                                |
| Notified AD/MAA or maintenance? If yes, who?                         | no                                |