

**From:** [donotreply@connect2mycloud.com](mailto:donotreply@connect2mycloud.com)  
**To:** [Moore, Steve](#)  
**Subject:** Form "Moseley Pool Chemical Log" Submission Received  
**Date:** Thursday, June 22, 2023 8:59:20 AM

---

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

## Form Submission

**DeSoto Parks and  
Recreation**

**Moseley Pool Chemical  
Log**

**Type :**Form

**User Type :**User

**Name :**PublicDesoto

**Link :**[Moseley Pool Chemical Log](#)

**Instructions :**Review and customize this form to meet your needs.

Questions	Response
Date of Reading	06.22.2023
Time of Reading	8:00 AM
Staff Member Taking Reading	Richmond Spencer Deep End CL - 3.1
Water Check - Free Chlorine (1.5 - 3.0 ppm)	3.3
pH Test (7.2 - 7.8)	7.3
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	40
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	245
Flow Rate	Good
ORP	755
Water Temperature (F)	71
Air Temperature (F)	88
Saturation Index	Good
Water Clarity	Great
Influent Pressure	25
Effluent Pressure	6

Pressure Differential	19
Chemicals and Amounts Added (Opening or Close)	None
Were any calibrations made? If yes, what was the calibration set as?	No
Any other notes/comments	No
Notified AD/MAA or maintenance? If yes, who?	No