

**From:** [donotreply@connect2mycloud.com](mailto:donotreply@connect2mycloud.com)  
**To:** [Moore, Steve](#)  
**Subject:** Form "Moseley Pool Chemical Log" Submission Received  
**Date:** Friday, June 23, 2023 9:09:36 AM

---

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

## Form Submission

**DeSoto Parks and  
Recreation**

**Moseley Pool Chemical  
Log**

**Type :**Form

**User Type :**User

**Name :**PublicDesoto

**Link :**[Moseley Pool Chemical Log](#)

**Instructions :**Review and customize this form to meet your needs.

Questions	Response
Date of Reading	06.23.2023
Time of Reading	8:30 AM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.8
pH Test (7.2 - 7.8)	7.3
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	45
Total Alkalinity (80-120 PPM)	115
Calcium Hardness (200-400 PPM)	225
Flow Rate	Good
ORP	352
Water Temperature (F)	71
Air Temperature (F)	88
Saturation Index	Good
Water Clarity	Great
Influent Pressure	24
Effluent Pressure	10
Pressure Differential	14

Chemicals and Amounts Added (Opening or Close)	Accu Tabs Will Be Added Before Opening
Were any calibrations made? If yes, what was the calibration set as?	no
Any other notes/comments	no
Notified AD/MAA or maintenance? If yes, who?	no

© 2023 Connect2Concepts LLC.All rights reserved.Version 1.22.4.21