

From: donotreply@connect2mycloud.com
To: [Moore, Steve](#)
Subject: Form "Moseley Pool Chemical Log" Submission Received
Date: Saturday, June 24, 2023 12:16:40 PM

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

Form Submission

**DeSoto Parks and
Recreation**

**Moseley Pool Chemical
Log**

Type :Form

User Type :User

Name :PublicDesoto

Link :[Moseley Pool Chemical Log](#)

Instructions :Review and customize this form to meet your needs.

| Questions | Response |
|---|------------|
| Date of Reading | 06.24.2023 |
| Time of Reading | 12:13 PM |
| Staff Member Taking Reading | Makayla |
| Water Check - Free Chlorine (1.5 - 3.0 ppm) | 1 |
| pH Test (7.2 - 7.8) | 7 |
| Total Chlorine = FC + CC | |
| Cyanuric Acid (30-50 ppm) | |
| Total Alkalinity (80-120 PPM) | |
| Calcium Hardness (200-400 PPM) | |
| Flow Rate | |
| ORP | 844 |
| Water Temperature (F) | 92 |
| Air Temperature (F) | |
| Saturation Index | |
| Water Clarity | |
| Influent Pressure | 14 |
| Effluent Pressure | 11 |
| Pressure Differential | 3 |

Chemicals and Amounts Added (Opening or Close)

Were any calibrations made? If yes, what was the calibration set as?

Any other notes/comments

Notified AD/MAA or maintenance? If yes, who?