



Export to PDF

DeSoto Parks and Recreation

Moseley Pool Chemical Log

F2023-3309809

Type: Form**User Type:** User**Date & Time:** 7/4/2023 12:51 PM**Name:** PublicDesoto**Instructions:** Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.04.2023
Time of Reading	12:49 PM
Staff Member Taking Reading	Michaela Greenly
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1
pH Test (7.2 - 7.8)	7
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	
ORP	650
Water Temperature (F)	
Air Temperature (F)	
Saturation Index	
Water Clarity	

Influent Pressure	23
Effluent Pressure	11
Pressure Differential	12
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	
Notified AD/MAA or maintenance? If yes, who?	