

From: donotreply@connect2mycloud.com
To: [Moore, Steve](#)
Subject: Form "Moseley Pool Chemical Log" Submission Received
Date: Wednesday, June 14, 2023 12:54:45 PM

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

Form Submission

DeSoto Parks and Recreation

Moseley Pool Chemical Log

Questions	Response
Date of Reading	06.14.2023
Time of Reading	12:50 PM
Staff Member Taking Reading	Richmond Spencer Deep Cl (1.0)
Water Check - Free Chlorine (1.5 - 3.0 ppm)	3.5
pH Test (7.2 - 7.8)	7.5
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	45
Total Alkalinity (80-120 PPM)	100
Calcium Hardness (200-400 PPM)	250
Flow Rate	Good
ORP	755
Water Temperature (F)	72
Air Temperature (F)	82
Saturation Index	Good
Water Clarity	Great
Influent Pressure	25
Effluent Pressure	8

Pressure Differential	17
Chemicals and Amounts Added (Opening or Close)	no
Were any calibrations made? If yes, what was the calibration set as?	no
Any other notes/comments	no
Notified AD/MAA or maintenance? If yes, who?	no