

**From:** [donotreply@connect2mycloud.com](mailto:donotreply@connect2mycloud.com)  
**To:** [Moore, Steve](#)  
**Subject:** Form "Moseley Pool Chemical Log" Submission Received  
**Date:** Tuesday, June 13, 2023 11:57:41 AM

---

You have received a completed Moseley Pool Chemical Log submission. Please see below details. If you have a Connect2 account, you can also access this through the online portal.

## Form Submission

**DeSoto Parks and  
Recreation**

**Moseley Pool Chemical  
Log**

**Type :**Form

**User Type :**User

**Name :**PublicDesoto

**Link :**[Moseley Pool Chemical Log](#)

**Instructions :**Review and customize this form to meet your needs.

Questions	Response
Date of Reading	06.13.2023
Time of Reading	11:47 AM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	2.0
pH Test (7.2 - 7.8)	7.3
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	45
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	250
Flow Rate	good
ORP	178
Water Temperature (F)	71
Air Temperature (F)	85
Saturation Index	good
Water Clarity	great
Influent Pressure	26
Effluent Pressure	8
Pressure Differential	18

Chemicals and Amounts Added (Opening or Close)	none
Were any calibrations made? If yes, what was the calibration set as?	no
Any other notes/comments	no
Notified AD/MAA or maintenance? If yes, who?	no

© 2023 Connect2Concepts LLC.All rights reserved.Version 1.22.4.19