

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2023-3297638

Type : Form

User Type : User

Date & Time : 6/27/2023 12:54 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	06.27.2023
Time of Reading	12:39 PM
Staff Member Taking Reading	Richmond Spencer
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.8
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	45
Total Alkalinity (80-120 PPM)	110
Calcium Hardness (200-400 PPM)	260
Flow Rate	Good
ORP	128
Water Temperature (F)	72
Air Temperature (F)	90
Saturation Index	Good
Water Clarity	Great
Influent Pressure	23
Effluent Pressure	13
Pressure Differential	10
Chemicals and Amounts Added (Opening or Close)	No
Were any calibrations made? If yes, what was the calibration set as?	No
Any other notes/comments	No
Notified AD/MAA or maintenance? If yes, who?	No