

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2024-4248115

Type : Form

User Type : User

Date & Time : 5/26/2024 1:17 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	05.26.2024
Time of Reading	
Staff Member Taking Reading	Matthew Reed
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.7
pH Test (7.2 - 7.8)	7.2
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	1
ORP	690
Water Temperature (F)	87
Air Temperature (F)	89
Saturation Index	
Water Clarity	Great
Influent Pressure	21
Effluent Pressure	14
Pressure Differential	7
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	Shallow area
Notified AD/MAA or maintenance? If yes, who?	Back washed hour ago