

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2024-4315078

Type : Form

User Type : User

Date & Time : 6/28/2024 10:02 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	06.28.2024
Time of Reading	10:01 AM
Staff Member Taking Reading	Brian Ray
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.1
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	1
ORP	760
Water Temperature (F)	93
Air Temperature (F)	87
Saturation Index	
Water Clarity	Great
Influent Pressure	16
Effluent Pressure	11
Pressure Differential	5
Chemicals and Amounts Added (Opening or Close)	
Were any calibrations made? If yes, what was the calibration set as?	
Any other notes/comments	Deep Area
Notified AD/MAA or maintenance? If yes, who?	