

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2025-5415028

Type : Form

User Type : User

Date & Time : 7/19/2025 1:41 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.19.2025
Time of Reading	1:39 PM
Staff Member Taking Reading	Christian Santiago
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.1
pH Test (7.2 - 7.8)	7.5
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	1
ORP	843
Water Temperature (F)	89
Air Temperature (F)	93
Saturation Index	
Water Clarity	Great
Influent Pressure	28
Effluent Pressure	19
Pressure Differential	9
Chemicals and Amounts Added (Opening or Close)	N/A
Were any calibrations made? If yes, what was the calibration set as?	N/A
Any other notes/comments	Deep End
Notified AD/MAA or maintenance? If yes, who?	