

# DeSoto Parks and Recreation

# Moseley Pool Chemical Log F2025-5436480

Type : Form

User Type : User

Date & Time : 7/30/2025 10:03 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

| Question   | Response                      |
|--|-------------------------------|
| Date of Reading  | 07.30.2025                    |
| Time of Reading  | 10:03 AM                      |
| Staff Member Taking Reading  | Matthew Reed                  |
| Water Check - Free Chlorine (1.5 - 3.0 ppm)                          | 1.8                           |
| pH Test (7.2 - 7.8)  | 7.4                           |
| Total Chlorine = FC + CC   |                               |
| Cyanuric Acid (30-50 ppm)  |                               |
| Total Alkalinity (80-120 PPM)  |                               |
| Calcium Hardness (200-400 PPM)                                       |                               |
| Flow Rate  | 1                             |
| ORP  | 761                           |
| Water Temperature (F)  | 78                            |
| Air Temperature (F)  | 92                            |
| Saturation Index   |                               |
| Water Clarity  | Great                         |
| Influent Pressure  | 30                            |
| Effluent Pressure  | 9                             |
| Pressure Differential  | 21                            |
| Chemicals and Amounts Added (Opening or Close)                       |                               |
| Were any calibrations made? If yes, what was the calibration set as? |                               |
| Any other notes/comments   | Shallow. Fill line turned off |
| Notified AD/MAA or maintenance? If yes, who?                         |                               |