

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2025-5437269

Type : Form

User Type : User

Date & Time : 7/30/2025 3:23 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.30.2025
Time of Reading	3:21 PM
Staff Member Taking Reading	Christian Santiago
Water Check - Free Chlorine (1.5 - 3.0 ppm)	1.0
pH Test (7.2 - 7.8)	7.5
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	1
ORP	628
Water Temperature (F)	83
Air Temperature (F)	101
Saturation Index	
Water Clarity	Great
Influent Pressure	30
Effluent Pressure	9
Pressure Differential	21
Chemicals and Amounts Added (Opening or Close)	N/A
Were any calibrations made? If yes, what was the calibration set as?	N/A
Any other notes/comments	Shallow End
Notified AD/MAA or maintenance? If yes, who?	