

# DeSoto Parks and Recreation

# Moseley Pool Chemical Log F2025-5377943

Type : Form

User Type : User

Date & Time : 7/1/2025 10:59 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.01.2025
Time of Reading	10:57 AM
Staff Member Taking Reading	Christian Santiago
Water Check - Free Chlorine (1.5 - 3.0 ppm)	2.8
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	1
ORP	761
Water Temperature (F)	76
Air Temperature (F)	85
Saturation Index	
Water Clarity	Great
Influent Pressure	30
Effluent Pressure	9
Pressure Differential	21
Chemicals and Amounts Added (Opening or Close)	N/A
Were any calibrations made? If yes, what was the calibration set as?	N/A
Any other notes/comments	Shallow End
Notified AD/MAA or maintenance? If yes, who?	