

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2025-5404773

Type : Form

User Type : User

Date & Time : 7/15/2025 10:18 AM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

Question	Response
Date of Reading	07.15.2025
Time of Reading	10:13 AM
Staff Member Taking Reading	Christian Santiago
Water Check - Free Chlorine (1.5 - 3.0 ppm)	2.5
pH Test (7.2 - 7.8)	7.4
Total Chlorine = FC + CC	
Cyanuric Acid (30-50 ppm)	
Total Alkalinity (80-120 PPM)	
Calcium Hardness (200-400 PPM)	
Flow Rate	1
ORP	752
Water Temperature (F)	74
Air Temperature (F)	84
Saturation Index	
Water Clarity	Great
Influent Pressure	27
Effluent Pressure	12
Pressure Differential	15
Chemicals and Amounts Added (Opening or Close)	N/A
Were any calibrations made? If yes, what was the calibration set as?	N/A
Any other notes/comments	Shallow End
Notified AD/MAA or maintenance? If yes, who?	