

DeSoto Parks and Recreation

Moseley Pool Chemical Log F2025-5423230

Type : Form

User Type : User

Date & Time : 7/23/2025 2:01 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

| Question | Response |
|--|---------------|
| Date of Reading | 07.23.2025 |
| Time of Reading | 2:01 PM |
| Staff Member Taking Reading | Anthony Silva |
| Water Check - Free Chlorine (1.5 - 3.0 ppm) | 1.0 |
| pH Test (7.2 - 7.8) | 7.4 |
| Total Chlorine = FC + CC | |
| Cyanuric Acid (30-50 ppm) | |
| Total Alkalinity (80-120 PPM) | |
| Calcium Hardness (200-400 PPM) | |
| Flow Rate | 1 |
| ORP | 658 |
| Water Temperature (F) | 79 |
| Air Temperature (F) | 93 |
| Saturation Index | |
| Water Clarity | Great |
| Influent Pressure | 28 |
| Effluent Pressure | 11 |
| Pressure Differential | 17 |
| Chemicals and Amounts Added (Opening or Close) | |
| Were any calibrations made? If yes, what was the calibration set as? | |
| Any other notes/comments | Shallow end |
| Notified AD/MAA or maintenance? If yes, who? | |