

# DeSoto Parks and Recreation

# Moseley Pool Chemical Log F2025-5455336

Type : Form

User Type : User

Date & Time : 8/9/2025 12:15 PM

Name : PublicDesoto

Instructions : Review and customize this form to meet your needs.

| Question   | Response         |
|--|------------------|
| Date of Reading  | 08.09.2025       |
| Time of Reading  | 12:14 PM         |
| Staff Member Taking Reading  | Richmond Spencer |
| Water Check - Free Chlorine (1.5 - 3.0 ppm)                          | 1.0              |
| pH Test (7.2 - 7.8)  | 7.6              |
| Total Chlorine = FC + CC   |                  |
| Cyanuric Acid (30-50 ppm)  |                  |
| Total Alkalinity (80-120 PPM)  |                  |
| Calcium Hardness (200-400 PPM)                                       |                  |
| Flow Rate  | Decent           |
| ORP  | 678              |
| Water Temperature (F)  | 76               |
| Air Temperature (F)  | 94               |
| Saturation Index   |                  |
| Water Clarity  | Good             |
| Influent Pressure  | 27               |
| Effluent Pressure  | 10               |
| Pressure Differential  | 17               |
| Chemicals and Amounts Added (Opening or Close)                       |                  |
| Were any calibrations made? If yes, what was the calibration set as? |                  |
| Any other notes/comments   |                  |
| Notified AD/MAA or maintenance? If yes, who?                         |                  |